

WOODMONT INDUSTRIAL, PBPOC PLAT 23/PARCEL E2 & K3/MAP 'E1' – STANDARD BUILDING SPECIFICATIONS 13133 BEELINE HWY, PALM BEACH PARK OF COMMERCE, JUPITER, FLORIDA May 7, 2025

Building Type	Single story, single loading distribution center
Building Area	±188,637 SF
Dimensions	300'-0" X 600'-0"
Clear Height	28'
Bay Sizes	 Typical: 50'-0" x 54'-0" Loading Dock: 54'-0" x 60'-0"
Car Parking	One-Hundred and Nineteen (119) spaces
Loading Docks	Thirty (30) docks Each dock position shall include: 9'-0" x 10'-0" steel vertical lift overhead doors on 2" horizontal track with vision panels and Z-guard track protection Dock Bumpers
Drive-In Doors	Two (2) drive-in doors Drive-in doors will be 12'-0" x 14'-0" steel lift-clearance, accessed via concrete ramp.
Truck Court	Overall length of ~486'-0" with 60'-0" deep concrete apron.
Pavement	Standard-duty asphalt pavement at car parking areas, heavy-duty asphalt pavement at truck court driveway, and heavy duty concrete pavement at loading dock aprons provided.
Floor Slab	7" reinforced concrete floor slab shall be provided.
Structural Frame	Steel joists and joist girders shall conform to industry specifications and be shop prime painted gray. Metal deck shall be galvanized with underside to be factory primed white.
Exterior Walls	 Site-cast concrete load bearing wall panels with insulation required to comply with energy codes. Panels shall include architectural reveals for accents and shall be painted. Exterior finish to receive Tex-Cote finish. All joints shall be caulked. Limited glazing at office areas. Clerestory windows shall be provided over warehouse area. High impact glass



Single-ply TPO membrane over R-19 rated, Polyiso rigid insulation board (to meet energy codes) mechanically attached to metal deck. A 20-year NDL manufacturer's warranty and 2-year contractor's workmanship warranty shall be provided. Roof securement shall meet building code and manufacturer requirements.
Hollow metal doors leading to exterior sidewalk, concrete stairs or concrete pads to grade as required by code.
ESFR fire suppression system with fire pump in accordance with NFPA and local codes shall be provided. Extinguishers shall be provided as required by the local fire marshal.
Warehouse Ventilation: code required ventilation shall be provided.
 Base Building LED light fixtures in warehouse designed for 30 FC light levels and emergency lighting meeting local code requirements. Building mounted light fixtures and site light poles to meet local requirements shall be provided. LED warehouse lighting positioned in accordance with steel structure.
Electrical service shall be provided. 2400 AMP service panel included in the base building.
Fire Alarm system for the building shell shall be provided per code.
Sanitary sewer service shall be provided to the building.
Domestic water service shall be provided for each tenant area. Fire sprinkler provided for the warehouse.
Roof drains and scuppers at the rear of the building, piped to underground stormwater drainage system.